

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7135-0569:0130

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** GENTEX CORPORATION, 10985 Chicago Drive, Zeeland, MI 49464  
Contact: Keiffer Sestric (616) 932-7195 Fax (616) 932-4219  
Email: keiffer.sestric@gentex.com

**DESIGN:** Model GEH12 horn and Model GEC3-12 multi-candela horn/strobes. May be followed by -W or -R (white or red) or -P plain. Model GEC3-12 horn/strobe is wall mounted. Both models are for indoor use. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 8-17.5 Vdc, 7-55 mA  
Candela: 15cd, 30cd, 60cd, 75cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela ratings, and UL label.

**APPROVAL:** Listed as horn and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

These units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.

**NOTE:**

01-12-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

*Listing Expires* **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
*Fire Engineering Division*