**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION**
**OFFICE OF THE STATE FIRE MARSHAL**
**FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM**

# LISTING SERVICE



**LISTING No.** 7320-0569:0137

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:**
Gentex Corporation10985 Chicago Drive, Zeeland, MI 49464
Contact: Keiffer Sestric (616) 392-7195 Fax (616) 392-4219
Email: keiffer.sestric@gentex.com

**DESIGN:** Model SSPKCLP ceiling *and wall mounted speaker. Model SSPK24CLP ceiling mounted speaker strobe. Models SSPKCLP and SSPK24CLP are available in red or white. Models are to be mounted in standard 4" X 2 1/8 " back boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

| | |
|---|---|
| Speaker | 25 Vrms and 70.7 Vrms |
| Strobe | 21-30 VDC |
| Flash Rate | 60 flashes per minute |
| Candela | 15, 30, 75, 95 and 115 cd |

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela ratings and UL label.

**APPROVAL:** Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Units with strobe lights are suitable for the hearing impaired applications. For indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:**

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013** *Listing Expires* **June 30, 2014**

Authorized By: ***JAMES PARSEGIAN**, Program Coordinator*

*Fire Engineering Division*