

SIEMENS

Kurzmitteilung/Fax

Herr Giese

Bosch Telekom GmbH

Per Fax: 02161-477 6091

7 Seiten

Fire & Security Products Siemens Gebäudesicherheit GmbH & Co. oHG

Name	Uwe Krohmann
Division	SGS
Abteilung	SGS P PS11
Standort	Mch F
Telefon	+49 (89) 636-58585
Fax	+49 (89) 636-58440

Unser Zeichen	
Datum	06. Juni 2002

Sehr geehrter Herr Giese,

als Anlage erhalten Sie Konformitätserklärung BAS No. Ex 98E2304
der British Approvals Service for Electrical Equipment in Flammable Areas
(vergleichbar mit der PTB in Deutschland)

Dort wurde das DS11-Melder System von Cerberus geprüft, das Zertifikat schließt
auch den Handfeuermelder DM1103B ein siehe S.2, Abschnitt 2.1.

Die Anforderungen der EN50020 Abschnitt 5.4 einfache elektrische Betriebsmittel
werden erfüllt, was auf der letzten Seite im Auszug aus dem Report No:96 (C) 1004
bestätigt wird.

Wir hoffe diese Dokumente helfen Ihnen weiter,
für weitere Rückfragen stehen wir Ihnen gerne zur Verfügung

Mit freundlichen Grüßen



Uwe Krohmann

British Approvals Service for Electrical
Equipment in Flammable Atmospheres



Certificate of Conformity

1

2

BAS No. Ex 98E2304

3 This certificate is issued for the intrinsically safe electrical system:

THE DS-11 Ex DETECTOR LOOP SYSTEM

4 Submitted for certification by:

SIEMENS BUILDING TECHNOLOGIES AG, CERBERUS DIVISION
of Alte Landstrasse 411, CH-8708, Männedorf, Switzerland

5 This electrical system and any acceptable variation thereto is specified in the Schedule to this Certificate and the documents therein referred to.

6 BASEEFA being an Approved Certification Body in accordance with Article 14 of the Council Directive of the European Communities of 18 December 1975 (76/117/EEC) certifies that the system has been found to comply with harmonised European Standards:

EN50 039: 1980

and has successfully met the examination and test requirements recorded in confidential Report number:

96(C)1004 dated 28 January 1999

7 The system is coded:

EEx ib IIC

8 It is the responsibility of the system certificate holder to supply the relevant documentation to the installer of the intrinsically safe electrical system referred to in this certificate.

The installer has the responsibility to ensure that the system conforms to the specification laid down in the Schedule to this certificate and has satisfied routine verifications and tests specified therein.

9 This system may be marked with the Distinctive Community Mark specified in Annex II to the Commission Directive of 16 January 1984 (Doc 84/47/EEC). A facsimile of this mark is printed on sheet 1 of this certificate.

File No: EECS 0205/02/005

Sheet 1 of 4

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the system may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on an EECS Manufacturing Licence.



I M CLEARE
DIRECTOR

12 February 1999



Registration Number
929
The use of the Accreditation
Mark indicates compliance with
the requirements of the International
Standard ISO 9001.



Electrical Equipment Certification Service
Health and Safety Executive
Harpur Hill, Buxton, Derbyshire. SK17 9JN, United Kingdom
Tel: 01298 28000 Fax: 01298 28244

British Approvals Service for Electrical
Equipment in Flammable Atmospheres



Schedule

Certificate of Conformity BAS No. Ex 98E2304

SYSTEM DESCRIPTION

A DS-11 Ex Detector Loop System comprising of:-

1. Apparatus located in the non-hazardous area (safe area).

1.1 Any one of the following shunt zener diode safety barriers

- a. A Type Stahl 9001/00-280-100-10 (28Vneg, 100mA) to PTB Certificate No. Ex-91.C.2046X
- b. A Type MTL 728 (28Vneg, 93mA) to BASEEFA Certificate No. Ex 832452
- c. A Type STL E85 (28Vneg, 93mA) to BASEEFA Certificate No. Ex 832072
- d. A Type Stahl 9001/01-280-100-10 (28Vpos, 100mA) to PTB Certificate No. Ex-91.C.2046X
- e. A Type MTL 728 (28Vpos, 93mA) to BASEEFA Certificate No. Ex 832452
- f. A Type STL E85 (28Vpos, 93mA) to BASEEFA Certificate No. Ex 832072
- g. A Type Stahl 9002/13-280-093-00 (28Vpos, 93mA: 28Vpos, diode return) to PTB Certificate No. Ex-91.C.2045X

An optional evaluation shunt zener diode safety barrier (Only to be used with a, b or c above)

- h. A Type Stahl 9001/04-086-000-10 (8.6Vneg, diode return) to PTB Certificate No. Ex-91.C.2045

1.3 Apparatus which is unspecified except that it must not be supplied from nor contain in normal or abnormal conditions a source of potential with respect to earth in excess of 250 volts r.m.s. or 250 volts d.c.

2. Apparatus which may be located in the Hazardous Area

2.1 Any number of Manual Call Point Types DM1101, DM1103 and DM1104 as detailed in BASEEFA Report No. 96(C)1004.

2.2 Up to 15 Smoke Detectors Type DQ1101A-Ex to PTB Certificate No. Ex-96.C.2060. Each smoke detector is to be used with a Detector Base Type DB1101A (and with any of following accessories:- DBZ1190, DBZ1190-AA, DBZ1191, DBZ1191A-AA, DBZ1192 and DBZ1194).

British Approvals Service for Electrical
Equipment in Flammable Atmospheres



Schedule

Certificate of Conformity BAS No. Ex 98E2304

The Smoke Detectors Type DO1101A-Ex may be used as part of the Air Sampling Smoke Detector Unit Type DBZ1197A (this being a mechanical arrangement which does not affect intrinsic safety)

- 2.3 Up to 25 Heat Detectors Type DT1101A-Ex or Type DT1102A-Ex to PTB Certificate No. Ex-95.C.2148. Each heat detector is to be used with a Detector Base Type DB1101A (and with any of following accessories:- DBZ1190, DBZ1190-AA, DBZ1191, DBZ1191A-AA, DBZ1192 and DBZ1194)
- 2.4 The Manual Call Point Types DM1101, DM1103 and DM1104, Smoke Detectors Type DO1101A-Ex, Heat Detectors Type DT1101A-Ex or Type DT1102A-Ex may be fitted with an End-of-line Device which may consist of one of the following:
- (i) A resistor ($4320\Omega \pm 5\%$, 1W) or an alternative value of resistor in accordance with drawing e4-5740-1.
 - (ii) An EOL22 (Ex) as detailed in BASEEFA Report No. 96(C)1004.

All of which must be installed such that the electrical circuit is provided with a degree of protection of at least IP20.

- 2.5 A Remote Indicator (LED) Type AJUT24 as detailed in BASEEFA Certificate Ex 862097 or Type DJ1191Ex or Type 1192Ex. as detailed in BASEEFA Certificate Ex 862097/6.

3. Permissible Interconnecting Cables.

- 3.1 The capacitance and either the inductance OR the inductance to resistance ratio (L/R) of the cable connected to the output terminals must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	L/R RATIO ($\mu\text{H}/\text{ohm}$)
All barriers except Stahl 9002/13-280-093-00			
IIC	0.045	3.0	55
IIB	0.315	11.6	165
IIA	0.535	32.6	440
Stahl 9002/13-280-093-00			
IIC	0.032	3.0	55
IIB	0.315	11.6	165
IIA	0.535	32.6	440

British Approvals Service for Electrical
Equipment in Flammable Atmospheres



Schedule

Certificate of Conformity BAS No. Ex 98E2304

The system does not consider the inclusion of the interconnecting wiring in a multi-core cable.

DRAWINGS

<u>Number</u>	<u>Sheet</u>	<u>Issue</u>	<u>Date</u>	<u>Description</u>
3-6827	-	*3	26.10.98	DS11-Ex Detector Loop System
4-521738-1	-	*2	26.10.98	System Label
@D4-457763	1	c	29.04.97	DM1101 Manual Call Point
@D4-457763	2	c	29.04.97	DM1101 Manual Call Point
@S4-485133	-	D1	06.10.95	DMA1103/DMA1104 Call Point
@M4-485272	-	A	01.07.96	DMA1103/DMA1104 Parts List
@X4-485272	-	B	03.07.95	Printed Circuit Board assembly
@X4-6873	-	*2	26.10.98	End of Line Device EOL22 (Ex)
@S4-516222	-	Orig.	08.10.96	End of Line Device EOL22 (Ex)
@M4-516222	-	Orig.	07.10.96	Parts List
@M4-516387	-	Orig.	07.10.96	Parts List
e4-5740-1	-	*1	05.05.97	End of line resistor
#R3.1678	-	-	17.11.78	AJUT 24 Ex LED Indicator
X2-6534	-	A	12.10.95	DB1101/DBZ1191/DBZ1192 base
X1367	-	-	09.95	DBZ1197 Air sampling detector unit
##X3-478344	-	-	21.02.94	Remote Indicator Type DJ1191Ex
##M4-478344 IND	-	-	02.10.95	Type DJ1191 Ex Parts List
##X3-478357	-	-	21.02.94	Remote Indicator Type DJ1192Ex
##M4-478357 IND	-	-	02.10.95	Type DJ1192 Ex Parts List
##S4-478373	-	-	21.03.94	Type DJ1191Ex and DJ1192 Ex Circuit


Drawing marked # are held on BASEEFA Certificate Ex 862097

Drawings marked ## are held on BASEEFA Certificate Ex 862097/6

Drawing marked @ are associated with BASEEFA Certificate Ex 862097/7

BASEEFA List Keywords

2ALARM



HAZARDOUS AREA
The Capacitance and Inductance or Inductance/Resistance Ratio of the hazardous area cables must not exceed the values shown in Table 2.
The installation must comply with additional requirements (eg. in the UK: BS5345: Part 4; IFTL).

NON HAZARDOUS AREA
Unspecified except that it must not be supplied from nor contain under normal or abnormal conditions a source of potential in respect to earth in excess of 250 V RMS

TABLE 2 MAXIMUM CABLE RATING

Group	Capacity μF	Inductivity $\mu H/cm$	L/R Ratio $\mu H/cm$
K	0.045	39	85
B	0.375	116	165
HA	0.535	326	440

for A3 (Start 9002/03-200-093-000 and 0872 AF only)
Remove indicators B1 and evaluation barriers B2 are NOT to be used in IEC-hazardous areas of MSHA this ground and bipolar systems.

Item	Component Type	Max. No.	Apparatus marking code	Tamb °C	Certificate No.
A 1	SAFETY BARRIER (ONE OFF) Either Start 9001/00-280-100-0 MIL780 Negative STLBS Negative or Start 9001/01-280-100-0 MIL780 Positive STLBS Positive	1	IEEx ia IIC IEEx ia IIC IEEx ia IIC IEEx ia IIC IEEx ia IIC IEEx ia IIC	≤ 40 ≤ 60 ≤ 45 ≤ 40 ≤ 60 ≤ 45 ≤ 40	PTB Ex-PIC204GX BAS Ex 032 45Z BAS Ex 032 07Z PTB Ex-PIC204GX BAS Ex 032 45Z BAS Ex 032 07Z PTB Ex-PIC204GX
A 2	EVALUATION BARRIER Start 9001/00-080-000-0	1 per LED	IEEx ia IIC	≤ 40	PTB Ex-PIC204GX
B	RESISTOR 470 Ohm/W or EOLZZ B4	1	Ex ia IIC T4 Ex ia IIC T4 Ex ia IIC T4	≤ 55 ≤ 70 ≤ 70	BAS Test Report 860100 BAS Report No 94037004
C	REMOTE INDICATOR LED Connected to B1 together with B1 or B2 AAUTZ4-Ex DJ1924-Ex, DJ1926-Ex	1 per det.	Ex ia IIC T4 Ex ia IIC T4 Ex ia IIC T4	≤ 55 ≤ 70 ≤ 70	BAS Test Report 860100 BAS Ex 032097/6 BAS Test Report 860100 BAS Ex 032097/6
D	SHIELD DETECTOR D0101A-Ex with detector base B1	5	Ex ia IIC T4 Ex ia IIC T4 Ex ia IIC T4	≤ 55 ≤ 70 ≤ 70	BAS Test Report 860100 BAS Ex 032097/6 BAS Test Report 860100 BAS Ex 032097/6
E	DETECTOR BASE D0101A-Ex, D0101A-Ex with detector base B1	25	Ex ia IIC T4 Ex ia IIC T4 Ex ia IIC T4	≤ 55 ≤ 70 ≤ 70	BAS Report No 94037004 BAS Report No 94037004
F	MANUAL CALL POINT D1901 D1903 D1904	25	Ex ia IIC T4 Ex ia IIC T4 Ex ia IIC T4	≤ 70	BAS Report No 94037004

1 Total number of H and J in any combination must not exceed 25 units
2 Simple apparatus according to EN60074 clauses 13 and 6.2
3 Special end-of-line resistor values see Fig. 46-5740-1

SCHEMATIC PRINCIPLE DIAGRAM
Intrinsically Safe DS11-Ex Detector Loop System

3-6827 *3

Siemens
CH - Mäntzschegg 1997
Copyright by SIEMENS
Carbenius Division

Erstf. Ers. f. Blatt 1


SECTION A TO EECs CERTIFICATION
REPORT No: 96(C)1004


1. **INTRODUCTION**

This report provides the basis for the assessment of an End of Line Device type EOL22 (Ex) as apparatus meeting the requirements of CENELEC Standards EN50 014: 1997 and EN50 020: 1994 with specific reference to clause 5.4 of EN50 020: 1994.

This report also provides the basis for the assessment of a Manual Call Point Types DM1101, DM1103 and DM1104 as apparatus meeting the requirements CENELEC Standards EN50 014: 1997 and EN50 020: 1994 with specific reference to clause 5.4 of EN50 020: 1994.

This report also provides the basis for certification of an DS-11 Ex Detector Loop System as an Intrinsically Safe System as defined in CENELEC Standard EN50 039: 1980 for Category Ib, Group IIC.



 = NICHT BESTUECKT
 = NON EQUIPE
 = NOT ASSEMBLED

© Copyright by Cerberus AG Maennedorf 1995

Ind.	Aend.	Ind.	Aend.	Ind.	Aend.	Ind.	Aend.	Ind.	Aend.	Ind.	Aend.	Ind.	Aend.	Ind.	Aend.
01	3.95/PFN	C	3.95/PFN	0	4.95/PFN	D1	TB40/95								

SCHALTEINSATZ
 UNITE DECL. MAN. D'ALARME } DMA1103A
 CALL POINT UNIT INTER. } DMA1104A

Messstab	Gezeichnet	28.02.1994	FAE
%	Gepuust	5.04.95	Hph
	Gesehen	6.10.95	Wj
Ersetzt durch:		Ersetzt fuer:	

Cerberus AG Maennedorf

S4-485133

Ind.
D1