



CERTIFICATE

No. Z2 04 01 48107 003

Holder of Certificate: Bosch Security Systems B.V.

Kapittelweg 10
4827 HG Breda
The Netherlands

Production Facility(ies): 48107

Certification Mark:



Product: EVAC Unit
(Digital Public Address and Emergency Sound System)

Model(s): Praesideo V2.x

Parameters:

Rated voltage:	100-120/220-240 V AC
Rated frequency:	50-60 Hz
Protection class:	I
Remark:	The certified product has to be installed by a qualified and authorized company to apply the mentioned standards below to the final installation which is not covered by this certificate. The check-list provided by the manufacturer must be filled out.

Tested according to: IEC 60849:1998
IEC 60065:1998
BS 5839-8:1998

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report no.: 028-70060587

Date, 2004-01-23

