消 防 處 牌 照 及 審 批 總 區

香港九龍尖沙咀東康莊道1號5樓 消防總部大廈

本處檔號 OUR REF.: (35) in FP 206/1192

來函檔號 YOUR REF.: J-005/C/022

電報掛號 TELEX:39607 HKFSD HX

電子郵件 E-mail < lcpolic2@hkfsd.gov.hk>

圖文傳真 FAX: 852-2723 2197 電 話 TEL NO.: 2733 7744



FIRE SERVICES DEPARTMENT LICENSING AND CERTIFICATION COMMAND

FIRE SERVICES HEADQUARTERS BUILDING, 5/F, No.1 Hong Chong Road, Tsim Sha Tsui East, Kowloon, Hong Kong.

17 June 2003

Bosch Security Systems Ltd. Fire Product Department 12/F, Metropole Square 2 On Yiu Street, Shatin N.T.

Dear Sirs,

Acceptance of Smoke Detectors

I refer to my interim reply of 22.4.2003 on the captioned subject.

The proposed use of the following detectors, which were certified by Underwriters Laboratories Inc. (UL), is considered acceptable to this Department:-

Manufacturer

Radionics Div. of Detection Systems Inc.

(Basically listed for Detection Systems Inc.)

Type

Addressable Smoke Detector, Photoelectric Type

Models

- (i) D7050
 - (ii) D7050TH (with an integral thermistor type, heat detector)
 - (iii) D7050DH (with condensed sensitivity limits)
 - (iv) D7040
 - (v) D7040TH (with an integral thermistor type, heat detector)
 - (vi) D7040THL (with an integral thermistor type heat detector and a low temperature alarm feature)

Testing Standard UL268

Supporting Documents

- (i) Test Report No. File S3019 Project 97NK26522 issued by UL on 11 May 1998 and latest revised on 14 August 2002.
- (ii) Multiple Listing Correlation Sheet File No. S4992 issued by UL on 1 April 1996 and latest revised on 22 April 2002 for test report file no. S3019 vol.2.

Please note that the above acceptance is subject to :-

- i) all conditions as stipulated in the above-mentioned test report being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) the components used in the installation being compatible.

Yours faithfully,

(LAU Kwai-shan)

for Director of Fire Services

LKS/TTW/lkc