

Certificate of Compliance

Certificate Number **20090401-S24615**
Report Reference **S24615, 2009-01-22**
Issue Date **2009-04-01**

Page 1 of 1



Issued to: **BOSCH SECURITY SYSTEMS B V**
KAPITTELWEG 10
BREDA
4827 HG, THE NETHERLANDS

*This is to certify that
representative samples of*

Speakers

Model Descriptions

Speaker enclosures, Models LBC 3080/01, LC1-MFD. Suitable for use in air-handling spaces.
Models LC1-CMR, LC1-CBB, LC1-CSMB. Suitable for indoor/dry use. The model LC1-CMR meets the applicable requirements only when installed in conjunction with the model LC1-CBB backbox.

Speakers, Models LC1-WM06E8, LC1-UM06E8, LC1-UM12E8, LC1-UM24E8. Suitable for indoor/dry use. Suitable for use in air-handling spaces when installed with the model LC1-MFD enclosure.

Model LHM 0606/00-US. Suitable for indoor/dry use. Suitable for use in air-handling spaces when installed with the model LBC 3080/01 enclosure.

Model LBC 3951/11-US. Suitable for indoor/damp use.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


The basic standard used to investigate products in this category is ANSI/UL 1480, "Speakers for Fire Alarm, Emergency, and Commercial and Professional Use."

The basic standard used to investigate nonmetallic materials of products marked suitable for use in air-handling spaces is UL 2043, "Fire Test for Heat and Visible Smoke Release for Discrete Products and Their Accessories Installed in Air-Handling Spaces."

Additional Information:

None

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: **Ronika Lal**

Reviewed by: **Daniel M Grosch**

Ronika Lal, Customer Service Professional
Underwriters Laboratories Inc.

Daniel M Grosch, Lead Engineer
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions in The United States of America you may call 1-877-UL-HELPS.