

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**1116-CPR-089-1**

*In compliance with Regulation (EU) N°305/2011 of 09/03/2011 laying down harmonised conditions for the marketing of construction products (Construction Products Regulation – CPR), it has been stated that the construction products below:*

### **PLN-24CH12 – BOSCH (Power Supply Equipment)**

<b>Main power supply:</b>	<b>230Vac-50Hz</b>
<b>Standby power supply:</b>	<b>Batteries of 24V (consists of blocks : 12 x 2V, 4 x 6V, 2 x 12V) / 38Ah at 225Ah</b>
<b>Final voltage of batteries:</b>	<b>21V</b>
<b>Number of outputs:</b>	<b>6 of 40A max / 3 of 5A max</b>
<b>Nominal voltage of outputs:</b>	<b>24V</b>
<b>Rated maximum continuous output current (I max a):</b>	<b>10.1A with battery of 38Ah / 0.75A with battery of 225Ah</b>
<b>Rated maximum short duration output current (I max b):</b>	<b>12A on sector / 150A on battery</b>
<b>Rated minimum output current:</b>	<b>0A</b>
<b>Type of power supply:</b>	<b>Switching mode</b>
<b>Switching frequency:</b>	<b>45Khz</b>
<b>Ripple voltage:</b>	<b>&lt;4%</b>

*placed on the market by*

**Bosch Security Systems B.V.**

Torenallee 49 - 5617BA - EINDHOVEN - THE NETHERLANDS

*and produced in the factory*

**SLAT**

11 rue Jean Elysée Dupuy - BP66-69543 CHAMPAGNE AU MONT D'OR - FRANCE

*are submitted by the manufacturer to a factory production control (FPC) and to further testing of samples taken at the factory in accordance with a prescribes test plan.*

*The approved body, CNPP Cert., has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the FPC and performs the continuous surveillance, assessment and approval of the FPC.*

**This certificate attests that all provisions concerning the assessment and verification of constancy of performance according to system 1 and the characteristics described in ZA annex of the standard EN 54-4:1997+A1:2002+A2:2006 were applied and that the product fulfils all prescribed requirements.**

*This certificate was first issued on 30/04/2019 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.*

On 30/04/2019

**Amaury LEQUETTE**  
Manager of CNPP Cert.