

Pasture Lane Clayton Bradford West Yorkshire
BD14 6LU England United Kingdom
Tel: +44(0)1274 882359 • Fax: +44(0)1274 882229
E-mail: info@thermocable.com



MANUFACTURERS DECLARATION OF CONFORMITY for

Product Identification

Model Type	AAE (all Variants)
Category (description)	Resettable line-type heat detector
Brand	Kidde, Alarmline II Analogue EN

Manufacturer

Thermocable Flexible Elements Ltd, Pasture Lane, Clayton, Bradford, BD14 6LU, United Kingdom

EU Representative

Thermocable (Flexible Elements) IRE Ltd, Ground Floor, 71 Lower Baggot Street, Dublin, D02 P593, Ireland
Tel: +44 (0)1274 882359 E-mail: AR@thermocable.com

Applicable Directives and Standards

Concerning	EMC 2014/30/EU
A sample of the product has been tested by	Eurofins York Ltd
Applied Standards	EN 50130-4:2011/A1:2014 EN61000-6-3:2007+A1:2011+AC:2012
	LVD 2014/35/EU Exempt from directive since operating voltage below 75Vdc and 50Vac

Equipment Class Identifier *(RF Products falling under the scope of R&TTE)*

Equipment Class Identifier Not Applicable None (Class 1 Product) (Class 2 Product)

Year of affixing the CE marking

2020

Means of conformity

we declare under our sole responsibility that this product is in conformity with Directive **2014/30/EU** (EMC), **93/68/EEC** (Marking) based on test results using harmonized standards in accordance with the Directives mentioned.

Environmental Directives

We also declare under our sole responsibility that this product is in conformity with the following Environmental Directives: **2011/65/EU** (RoHS2), **2015/863** (RoHS3) and Directive **2012/19/EU** (WEEE)

Thermocable

Flexible Elements Ltd

Pasture Lane Clayton Bradford West Yorkshire
BD14 6LU England United Kingdom

Tel: +44(0)1274 882359 • Fax: +44(0)1274 882229

E-mail: info@thermocable.com

Model Listing

AAECU - Alarmline II Analogue EN Controller
AAECU-EOL - Alarmline II Analogue EN EOL Unit
AAECU-JUN - Alarmline II Analogue EN Junction box
AAE-xxxx - Alarmline II Analogue EN PVC Sensor Cable
(where xxxx can be 0100 or 0500)


Signed for and on behalf of the manufacturer by:

Philip Wilkie – Manufacturing & Compliance Director

.....
(name and function)

Thermocable Flexible Elements Ltd
on 13th August 2021

.....
..
(placed and date of issue)



.....
(signature)