

消 防 處  
牌 照 及 審 批 總 區  
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓  
消 防 總 部 大 廈



**FIRE SERVICES DEPARTMENT  
LICENSING AND CERTIFICATION  
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,  
5/F, No.1 Hong Chong Road,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong.

本處檔號 OUR REF.:(41) in FP 206/1192  
來函檔號 YOUR REF.: J-005/C/024  
電報掛號 TELEX:39607 HKFSD HX  
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>  
圖文傳真 FAX: 852-2367 3631  
電 話 TEL NO.: 2733 7744

23 June 2003

Bosch Security Systems Ltd.  
12/F, Metropole Square,  
2 On Yiu Street,  
Shatin, NT

Dear Sirs,

**Acceptance of Smoke Detector**

I refer to my interim reply of 22.4.2003 on the captioned subject.

Please be informed that the following detectors, which were certified by Underwriters Laboratories Inc., are acceptable to this Department:-


<b>Manufacturer</b>	:	Radionics Div of Detection Systems Inc. (basically listed for Detection Systems Inc.)
<b>Type</b>	:	Smoke automatic fire detector projected beam
<b>Models</b>	:	D296 and D297
<b>Testing Standard</b>	:	UL 268 – Smoke Detectors for Fire Protective Signaling Systems
<b>Supporting Documents</b>	:	i) Test Report File S3019 Project 89NK23905 issued by UL on 27.12.1989 and latest revised on 4.2.2002 ii) Multiple Listing File No. S4992 issued by Underwriters Laboratories Inc. on 1.4.1996 and revised on 13.7.1999

.../P2

Please note that the above acceptance is subject to :

- i) all conditions as stipulated in the above-mentioned Test Report and Multiple Listing Correlation Sheet being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002, Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) the components used in the installation being compatible.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'LAU Kwai-shan', written in a cursive style.

(LAU Kwai-shan)  
for Director of Fire Services

LKS/TTW/lcm