

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION
COMMAND

FIRE SERVICES HEADQUARTERS BUILDING,
5/F, No.1 Hong Chong Road,
Tsim Sha Tsui East, Kowloon,
Hong Kong.

本處檔號 OUR REF.: (50) in FP 206/1192
來函檔號 YOUR REF.: J-005/C/029
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>
圖文傳真 FAX: 852-2367 3631
電 話 TEL NO.: 2733 7605

22 August 2003

Bosch Security Systems Ltd.
Fire Product Department,
12/F, Metropole Square,
2 On Yiu Street, Shatin,
NT

Dear Sirs,

Acceptance of Electromagnetic Door Releases

I refer to my interim reply of 7.7.2003 on the captioned subject.

Please be informed that the following equipment, which were certified by Underwriters Laboratories Inc. (UL), are acceptable to this Department:-


- Manufacturer** : Radionics, Div of Detection Systems Inc
(basically listed for RSG Inc)
- Type** : Electromagnetic Door Release
- Models** : D370B, D370C,
D371B, D371C,
D372B, D372C
- Testing Standard** : UL 864, Eighth Edition
- Supporting Documents** : i) Multiple Listing File No. S6162 issued by UL
on 23.4.1996 and revised on 5.10.2000; and
ii) Test Report File S2985 Project 84NK18561
issued by UL on 28.11.1984 and latest revised
on 20.11.1996

...../P2

Please note that the above acceptance is subject to :

- i) all conditions as stipulated in the above-mentioned Test Report and Multiple Listing Correlation Sheet being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002, Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) the components used in the installation being compatible.

Yours faithfully,



(LAU Kwai-shan)
for Director of Fire Services

LKS/YWK/lcm