

消防處
牌照及審批總區
香港九龍尖沙咀東康莊道1號5樓
消防總部大廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, 5/F,
Tsim Sha Tsui East Kowloon,
Hong Kong.

本處檔號 OUR REF. : (3) in FP 206/1207
來函檔號 YOUR REF. : J-002/C/067
電子郵件 E-mail : <lcpolice2@hkfsd.gov.hk>
圖文傳真 FAX : 852-2367 3631
電話 TEL NO. : 2733 7557

31 May 2004

Bosch Security Systems Ltd.
Fire Product Department
12/F, Metropole Square
2 On Yiu Street, Shatin
N.T.

Dear Sirs,

Acceptance of Detectors

I refer to my interim reply of 15.4.2004 on the captioned subject.

The proposed use of the following detectors, which were certified by Underwriters Laboratories Inc. (UL), is acceptable to this Department :-

Manufacturer	: Bosch Security Systems Inc.
i) Type	: Smoke detector
Models	: (i) F220-PTH (conventional photoelectric type with an integral 135°F fixed temperature, thermistor type, heat detector); (ii) F220-P (conventional photoelectric type).
Testing Standard	: UL268
Supporting Document	: Test Report No. File S3019 Project 03NK09016 issued by UL on 9 November 2003 and latest revised on 16 December 2003.
Remark	: To be used in conjunction with models F220-B6, F220-B6C, F220-B6R and F220-B6E detector bases.


.../P.2

- Manufacturer** : Bosch Security Systems Inc.
- ii) **Type** : Electronic fixed temperature heat detector
- Models** : (i) F220-135F (135°F Fixed);
(ii) F220-190F (190°F Fixed);
(iii) F220-135 (Combination 15°F Rate of Rise and 135°F Fixed).
- Testing Standard** : UL521
- Supporting Document** : Test Report No. File S8492 Project 03CA21413 issued by UL on 5 February 2004.
- Remark** : To be used in conjunction with models F220-B6, F220-B6C, F220-B6R and F220-B6E detector bases.
- iii) **Type** : Smoke detector
- Models** : (i) F220-PTHC (conventional photoelectric type with an integral 135 °F fixed temperature, thermistor type, heat detector) ;
(ii) F220-PC (conventional photoelectric type).
- Testing Standard** : UL268
- Supporting Document** : Test Report No. File S3019 Project 03CA28804 issued by UL on 13 February 2004.
- Remarks** : To be used in conjunction with models F220-B6, F220-B6C, F220-B6R and F220-B6E detector bases.

Please note that the above acceptance is subject to :-

- i) all conditions as stipulated in the above-mentioned test reports being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) the components used in the installation being compatible.

Yours faithfully,



(LAU Kwai-shan)

for Director of Fire Services