

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
FIRE SERVICES HEADQUARTERS BUILDING,
5/F, No.1 Hong Chong Road,
Tsim Sha Tsui East, Kowloon,
Hong Kong.

本處權號 OUR REF. : (57) in FP 206/1192
來函權號 YOUR REF. : J-005/C/035 & J-005/C/038
電子郵件 E-mail : <lcpoli2@hkfsd.gov.hk>
圖文傳真 FAX : 2367 3631
電 話 TEL NO. : 2733 7557

12 November 2004

Bosch Security Systems Ltd.
12/F, Metropole Square,
2 On Yiu Street,
Shatin, N.T.

Dear Sirs,

Acceptance of Motor Bells

I refer to my interim reply of 19.8.2004 and your latest submission of 26.10.2004 on the captioned subject

The proposed use of the following motor bells, which were certified by Underwriters Laboratories Inc. (UL), is acceptable to this Department:-

- Manufacturer** : Bosch Security Systems Inc.
(Basically listed for Wheelock Inc.)
- Type** : Motor Bell
- Models** : D440
MB-G6-12-R
D441
MB-G6-24-R
D442
MB-G10-12-R
D443
MB-G10-24-R
- Testing Standard** : UL 464
- Supporting Document** : (i) Test Report File E5946 Project 96NK33238
issued by UL on 4.12.1996 and lastest revised on
15.4.2004
(ii) Multiple Listing Correlation Sheet File No. S3391
issued by UL on 16.10.1991 and revised on
29.7.2004.

...../2

Please note that the above acceptance is subject to :

- i) all conditions as stipulated in the above-mentioned test report being complied with;
- ii) the installation conforming to FSD Circular Letter No. 1/2002, Rules for Fire Detection and Alarm Systems for Buildings; and
- iii) all components used in the installation being compatible.

Yours faithfully,



(LO Chun-hung)
for Director of Fire Services

LCH/TTW/lkc