

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 26-02-E Vol. II
Report of Material and Equipment Acceptance Division

Manufacturer – Radionics, 130 Perinton Parkway, Fairport, NY 14450.
Trade Name – Radionics.
Product – Devices for fire alarm control.
Pertinent Code Section(s) – Reference Standard RS 17-3, RS 4-6 (886-69-BCR).
Tests – UL 286.
Laboratory – Underwriters Laboratories, Inc.
Test Reports – File S5579, Project 00NK25441, issued May 4, 2001.
Description – Fire Alarm Equipment:

Model No.	Description
D9068	Digital Alarm Communicator Transmitter
D9068LC	Dialer Motherboard
AE203R	Enclosure

Multiple Listing – D7033, Keypad Annunciator for Siemens DCT-P. Five Channel Digital Communicator ML File No. S1510, Iss. August 30, 2001
MEA 12-92-E Vol. 12.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated June 30, 2003, F.P. Index No. 0306020.

Recommendation- That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3, the manufacturer's recommendations, NFPA 72, and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 1, 2003
Examined by [Signature]

⊗