



BOSCH

November 01, 2016

130 Perinton Parkway
Fairport NY, 14450
Telephone +1 800 289 0096
Telefax +1 585 223 9180
security.sales@us.bosch.com
www.Bosch.us

D8109 Fire Enclosure

This product has been tested by Underwriters Laboratories under the following Underwriters Laboratories of Canada (ULC) standards (listed in parentheses) and listed under the indicated ULC Category Codes and File Numbers. Place your cursor on the Category Code and File Number that you want to access in the following list and click the left mouse button to go directly to the ULC Online Certifications Directory listing for that Category Code and File Number. The standards to which this product was evaluated are listed in parentheses.

[AOTX7.S1871](#), Local Alarm Units Certified for Canada (CAN/ULC-S303 Local Burglar Alarm Units and Systems and CAN/ULC-S525 Audible Signal Devices for Fire Alarm Systems, Including Accessories)

[APAW7.S1871](#), Police-station-connected Alarm Units Certified for Canada (CAN/ULC -S303 Local Burglar Alarm Units and Systems, CAN/ULC-S304 Signal Receiving Centre and Premise Burglar Alarm Control Units, and CAN/ULC-S525 Audible Signal Devices for Fire Alarm Systems, Including Accessories)

[NBSX7.S1871](#), Household Burglar Alarm System Units Certified for Canada (ULC/ORD-C1023 Preliminary Standard for Household Burglar Alarm System Units)