


D113 Module de supervision, câble batterie

www.boschsecurity.com



Certifications et homologations

Zone	Conformité aux réglementations/ labels de qualité	
États-Unis	UL	AMCX: Central Station Alarm Units (ANSI/UL 1610 and ANSI/UL 1635), AOTX: Local Alarm Units (ANSI/UL 609 and ANSI/UL 464), APOU: Proprietary Alarm Units (ANSI/UL 1076), NBSX: Household Burglar Alarm System Units (ANSI/UL 1023), UOXX: Control Unit Accessories, System (ANSI/UL 864), and UTOU: Control Units and Accessories, Household System Type (ANSI/UL 985)
	UL	UL 985 - Household Fire Warning System Units (6th edition)
	CSFM	California State Fire Marshal

Zone	Conformité aux réglementations/ labels de qualité	
	NYC-MEA	12-92-E, Vol. XII
	NYC-MEA	12-92-E, Vol. XV

Informations de commande

D113 Module de supervision, câble batterie

Le D113 supervise le câblage de deux batteries de 12 volts raccordées au même jeu de bornes de chargement.

Numéro de commande **D113**