



# FAA-420-RI Remote Indicator



The external detector alarm display should be mounted in corridors or access pathways of the corresponding building sections or rooms.

## Certifications and Approvals

Region	Certification
Europe	CE FAA-420-RI

## Installation/Configuration Notes

**Note** If unshielded cables are used, the cable length between an LSN detector and an external detector alarm display is restricted to a maximum of 3 m.  
If shielded cables are used, make sure that the total cable length does not exceed 500 m (= sum of all cables to the external detector alarm display within one loop or stub).

## Technical Specifications

Operating voltage	5 V DC . . . 30 V DC
Maximum current consumption	20 mA
Display medium	2 LEDs
Permissible wire gauge	0.6 mm – 2.0 mm
Dimensions	84 x 84 x 35 mm
Weight	45 g
Protection class as per IEC 60529	IP 40

## Ordering Information

**FAA-420-RI Remote Indicator** **FAA-420-RI**  
required if the detector is not directly visible or has been mounted in false ceilings or false floors

**Americas:**  
Bosch Security Systems, Inc.  
130 Perinton Parkway  
Fairport, New York, 14450, USA  
Phone: +1 800 289 0096  
Fax: +1 585 223 9180  
security.sales@us.bosch.com  
www.boschsecurity.us

**Europe, Middle East, Africa:**  
Bosch Security Systems B.V.  
P.O. Box 80002  
5600 JB Eindhoven, The Netherlands  
Phone: + 31 40 2577 284  
Fax: +31 40 2577 330  
emea.securitysystems@bosch.com  
www.boschsecurity.com

**Asia-Pacific:**  
Robert Bosch (SEA) Pte Ltd, Security Systems  
11 Bishan Street 21  
Singapore 573943  
Phone: +65 6258 5511  
Fax: +65 6571 2698  
apr.securitysystems@bosch.com  
www.boschsecurity.com

**Represented by**