



D1625 Transformator



Certyfikaty i świadectwa

Region	Certyfikacja
Stany Zjednoczone	UL UOXX: Control Unit Accessories, System (UL864, 9th edition) CSFM 7167-1615: 124 July 2008

Zamówienia - informacje

D1625 Transformator

Transformator 16 VAC, 25 VA wymagany do zasilania central D2212B i D2212BE.

D1625

Poland
Robert Bosch Sp. z o.o.
Jutrzenki 105 str.
02-231 Warszawa
Phone: +48 22 715 4101
Fax: +48 22 715 4105
pl.securitysystems@bosch.com
www.boschsecurity.pl

Represented by