

Conventional Interface Modules 4-wire LSN

FLM-420/4-CON-S | FLM-420/4-CON-D



de deutsch
en english

| | | |
|-------------------|----------------------|----------|
| de deutsch | Kompatibilitätsliste | 4 |
| en english | Compatibility List | 6 |

1 Kompatibilitätsliste

Die in der nachfolgenden Liste aufgeführten Geräte können an folgende Koppler angeschaltet werden:

- FLM-420/4-CON-S
- FLM-420/4-CON-D

Die folgenden Geräte sind getestet und kompatibel. Bosch Sicherheitssysteme GmbH erhebt keinen Anspruch auf Vollständigkeit der Liste. Für aktuelle Informationen wenden Sie sich bitte direkt an Bosch Sicherheitssysteme GmbH.



Hinweis!

Für eine EN 54-13 konforme Anschaltung von 2-Draht-Meldern muss das FLM-320-EOL2W EOL-Modul GLT 2-Draht eingesetzt werden.

Für eine EN 54-13 konforme Anschaltung von 4-Draht-Meldern muss das FLM-320-EOL4W EOL-Modul GLT 4-Draht eingesetzt werden.

Anschaltbar ab Modul-Firmware 1.1.10; Version der Zentralensoftware beachten.



Hinweis!

Die mit ¹⁾ gekennzeichneten Geräte dürfen nur an die GLT-Koppler FLM-420/4-CON-S/-D angeschlossen werden, wenn die Meldelinien als Stich (Class B) programmiert sind. Ring-Konfiguration (Class A) ist hier nicht zulässig. Anschaltbar ab Koppler-Firmware 1.4; Version der Zentralensoftware beachten.

Die mit ²⁾ gekennzeichneten Geräte erfordern einen Vorwiderstand mit dem angegebenen Wert.

Bei den mit ³⁾ gekennzeichneten Geräten ist kein Melderblinker erlaubt.

Automatische GLT-Brandmelder

| |
|---|
| 601PH + SMP69 |
| BD102 O |
| BR10 ¹⁾ / BR12 ¹⁾ |
| DP652 ¹⁾³⁾ |
| DT654 ¹⁾³⁾ |
| F732 ¹⁾ |
| FCP-320/FCH-320 |
| FCP-500 |
| GIM 120 |
| GOM 120 |
| GTM 120 |
| MAGIC.SENS 300/310 |
| ORM 130/8-Ex |

Manuelle GLT-Melder

| |
|---------|
| DKM 120 |
| DM700LB |

| |
|-------------|
| FMC-120-DKM |
| FMC-300RW |
| SKM 120 |
| SM 120 RW |

Sondermelder

| |
|--------------------------------------|
| ADW 511A |
| DF 1192 ¹⁾²⁾ [270 Ω, 1 W] |
| FCH-heat-bar |
| FCS-LWM-1 |
| Fireray 50/100RV |
| Fireray 2000 |
| Fireray 5000 |
| LHD 4 |
| RAS-XL |
| Transsafe ADW 511 |
| UV-185/4 ¹⁾³⁾ |
| FCS-320-TM |
| FCS-320-TP |
| N4387A |

Erweiterung zum Anschluss von Siemens-Meldern für Ex-Bereich

| |
|---|
| S24211 - J118 - A60 ¹⁾ |
| SB3/DCA 1192 ¹⁾²⁾ [330 Ω, 1 W] |

1 Compatibility List

The devices in the following list can be connected to the following Interface Modules:

- FLM-420/4-CON-S
- FLM-420/4-CON-D

The following devices have been tested and are compatible. Bosch accepts no liability for any incompleteness in this list and so for the definitive and latest information it is advisable to contact Bosch Security Systems Inc. directly.



Notice!

For 2-wire connections complying with EN 54-13, the FLM-320-EOL2W Conventional EOL Module 2-Wire must be applied.

For 4-wire connections complying with EN 54-13, the FLM-320-EOL4W Conventional EOL Module 4-Wire must be applied.

Connectable with firmware version 1.1.10 and above; please observe panel software version.



Notice!

All devices marked with ¹⁾ can be connected to the FLM-420/4-CON-S/-D Conventional Interface Module only if the detector lines are programmed as stubs (Class B). Loop configurations are not allowed. Connectable with firmware version 1.4 and above; please observe panel software version.

All devices marked with ²⁾ require a series resistor with the value indicated.

All devices marked with ³⁾ are not allowed to use the Flashing LED option.

Conventional Automatic Fire Detectors

| |
|---|
| 601PH + SMP69 |
| BD102 O |
| BR10 ¹⁾ / BR12 ¹⁾ |
| DP652 ¹⁾³⁾ |
| DT654 ¹⁾³⁾ |
| F732 ¹⁾ |
| FCP-320/FCH-320 |
| FCP-500 |
| GIM 120 |
| GOM 120 |
| GTM 120 |
| MAGIC.SENS 300/310 |
| ORM 130/8-Ex |

Conventional Manual Call Points

| |
|-------------|
| DKM 120 |
| DM700LB |
| FMC-120-DKM |

| |
|-----------|
| FMC-300RW |
| SKM 120 |
| SM 120 RW |

Specialty Detectors

| |
|--------------------------------------|
| ADW 511A |
| DF 1192 ¹⁾²⁾ [270 Ω, 1 W] |
| FCH-heat-bar |
| FCS-LWM-1 |
| Fireray 50/100RV |
| Fireray 2000 |
| Fireray 5000 |
| LHD 4 |
| RAS-XL |
| Transsafe ADW 511 |
| UV-185/4 ¹⁾³⁾ |
| FCS-320-TM |
| FCS-320-TP |
| N4387A |

Accessory for connection of Siemens Detectors for ex-area

| |
|---|
| S24211 - J118 - A60 ¹⁾ |
| SB3/DCA 1192 ¹⁾²⁾ [330 Ω, 1 W] |



Bosch Sicherheitssysteme GmbH

Robert-Bosch-Ring 5

85630 Grasbrunn

Germany

www.boschsecurity.com

© Bosch Sicherheitssysteme GmbH, 2018